

Wireless Thermocouple and Temperature/Humidity Sensor

R718CXAB User Manual

Copyright©Netvox Technology Co., Ltd.

This document contains proprietary technical information which is the property of NETVOX Technology. It shall be maintained in strict confidence and shall not be disclosed to other parties, in whole or in part, without written permission of NETVOX Technology. The specifications are subject to change without prior notice.

Table of Contents

1. Introduction.....	2
2. Appearance.....	3
3. Features	3
4. Set up Instruction	4
5. Data Report	5
5.1 Example of ReportDataCmd	5
5.2 Example of ConfigureCmd.....	7
5.3 Example of GlobalCalibrateCmd	8
5.4 Set/GetSensorAlarmThresholdCmd.....	9
5.5 Example for MinTime/MaxTime logic	10
6. Information about Battery Passivation	11
6.1 To determine whether a battery requires activation	11
6.2 How to activate the battery.....	11
7. Important Maintenance Instruction.....	12
8. Description of Waterproof Grade	13

1. Introduction

R718CKAB: The temperature/humidity sensor and K-type thermocouple can respectively detect the temperature and humidity, and an object's surface temperature. The temperature measurement range of R718CK is $-40\text{ }^{\circ}\text{C}$ to $+375\text{ }^{\circ}\text{C}$. R718CK has the features of good linearity, larger thermal electromotive force, high sensitivity and stability. It should not be used in sulfuric environments, reducing, oxidizing, and vacuum atmospheres, or weak oxidizing atmosphere.

R718CTAB: The temperature/humidity sensor and T-type thermocouple can respectively detect the temperature and humidity, and an object's surface temperature. The temperature measuring range of R718CT is $-40\text{ }^{\circ}\text{C}$ to $+125\text{ }^{\circ}\text{C}$ but it works more stably in the range of $-40\text{ }^{\circ}\text{C}$ to $0\text{ }^{\circ}\text{C}$.

R718CNAB: The temperature/humidity sensor and N-type thermocouple can respectively detect the temperature and humidity, and an object's surface temperature. The temperature measuring range of R718CK is $-40\text{ }^{\circ}\text{C}$ to $+800\text{ }^{\circ}\text{C}$, which is wider than other types of thermocouples.


LoRa Wireless Technology:

LoRa is a wireless communication technology that adopts techniques such as long-distance communication and low power consumption. Compared with other communication methods, LoRa spread-spectrum modulation techniques greatly expand the communication distance. It is used in long-distance and low-data wireless communications like automatic meter reading, building automation equipment, wireless security systems, and industrial monitoring control system. The features include small size, low power consumption, long transmission distance, and anti-interference ability.

LoRaWAN:

LoRaWAN built LoRa's end-to-end standards and techniques, ensuring interoperability between devices and gateways from different manufacturers.


2. Appearance



R718CKAB



R718CTAB



R718CNAB

3. Features

- SX1276 wireless communication module
- 2 ER14505 battery in parallel (AA size 3.6V/for each battery)
- IP65 rating
- Magnetic base
- Thermocouple detection
- Temperature/Humidity detection
- Compatible with LoRaWAN™ Class A device
- Frequency hopping spread spectrum
- Support third-party platforms: Actility/ThingPark, TTN, MyDevices/Cayenne
- Low-power design for longer battery life

Note:

Please refer to http://www.netvox.com.tw/electric/electric_calc.html for battery life calculation and other detailed informatio

4. Set up Instruction

On/Off

Power on	Insert batteries. (Users may need a screwdriver to open battery cover.)
Turn on	Press and hold the function key for 3 seconds until the green indicator flashes.
Turn off (Reset to factory setting)	Press and hold the function key for 5 seconds until green indicator flashes fast for 20 times.
Power off	Remove Batteries.
Note	<ol style="list-style-type: none"> 1. When user removes and inserts the battery; the device should be off by default. 2. 5 seconds after power on, the device will be in engineering test mode. 3. On/off interval is suggested to be about 10 seconds to avoid the interference of capacitor inductance and other energy storage components.

Network Joining

Never joined the network	<p>Turn on the device to search the network to join.</p> <p>The green indicator stays on for 5 seconds: Success</p> <p>The green indicator remains off: Fail</p>
Had joined the network (without factory resetting)	<p>Turn on the device to search the previous network to join.</p> <p>The green indicator stays on for 5 seconds: Success</p> <p>The green indicator remains off: Fail</p>
Fail to join the network	User is recommended to check the device verification information on the gateway or consult your platform server provider.

Function Key

Press and hold for 5 seconds	<p>Reset to factory setting/Turn off</p> <p>The green indicator flashes 20 times: Success</p> <p>The green indicator remains off: Fail</p>
Press once	<p>The device is in the network: green indicator flashes once and sends a report.</p> <p>The device is not in the network: green indicator remains off</p>

Sleeping Mode

The device is on and in the network	<p>Sleeping period: Min Interval.</p> <p>When the reportchange exceeds the setting value or the state changes, the device will send a data report based on the Min Interval.</p>
-------------------------------------	--

Low Voltage Warning

Low Voltage	3.2 V
-------------	-------

5. Data Report

The device will immediately send a version packet report along with an uplink packet including temperature and battery voltage.

The device sends data based on the default configuration before any configuration is done.

Default:

Max Interval: 0x0384 (900s)

Min Interval: 0x0384 (900s) (Automatically checking the current voltage every Min Interval)

BatteryChange: 0x01 (0.1V)

TemperatureChange:0x01 (1°C)

AirTemperatureChange: 0x01 (1°C)

AirHumidChange: 0x01 (1%)

Note:

1. The interval of the data reports might vary due to the firmware.
2. The interval between two reports must be the minimum time.
3. Please refer to the Netvox LoRaWAN Application Command and <http://www.netvox.com.cn:8888/cmddoc> for devices' data analysis.

Data report configuration and sending period are as following:

Min Interval (Unit: second)	Max Interval (Unit: second)	Reportable Change	Current Change \geq Reportable Change	Current Change $<$ Reportable Change
Any number between 1~65535	Any number between 1~65535	Cannot be 0.	Report per Min Interval	Report per Max Interval

5.1 Example of ReportDataCmd

FPort: 0x06

Bytes	1	1	1	Var(Fix=8 Bytes)
	Version	DeviceType	ReportType	NetvoxPayLoadData

Version– 1 byte –0x01—the Version of NetvoxLoRaWAN Application Command Version

DeviceType– 1 byte – Device Type of Device

The devicetype is listed in Netvox LoRaWAN Application Devicetype doc

ReportType – 1 byte –the presentation of the NetvoxPayLoadData, according the devicetype

NetvoxPayLoadData– Fixed bytes (Fixed =8bytes)

Tips

1. Battery Voltage:

The voltage value is bit 0 ~ bit 6, bit 7=0 is normal voltage, and bit 7=1 is low voltage.

Battery=0xA0, binary=1010 0000, if bit 7= 1, it means low voltage.

The actual voltage is 0010 0000 = 0x20 = 32, 32*0.1v =3.2v

2. Version Packet:

When Report Type=0x00 is the version packet, such as 01C4000A0B202005200000, the firmware version is 2020.05.20

3. Data Packet:

When Report Type=0x01 is data packet.

4. Signed Value:

When the temperature is negative, 2's complement should be calculated.

Device	Device Type	Report Type	NetvoxPayloadData				
R718CKAB	0xC4	0x01	Battery	Temperature	AirTemperature	AirHumidity	ThresholdAlarm(1Byte)
R718CTAB	0xC5		(1Byte)	(Signed2Bytes)	(Signed2Bytes)	(2Bytes)	Bit0_LowTemperatureAlarm
R718CNAB	0xCE		unit:0.1V	unit:0.1°C	unit:0.01°C	unit:0.01%	Bit1_HighTemperatureAlarm
							Bit2_LowAirTemperatureAlarm
							Bit3_HighAirTemperatureAlarm
							Bit4_LowAirHumidityAlarm
							Bit5_HighAirHumidityAlarm
							Bit6-7:Reserved

Example of Uplink: 01C40124028A0B0E1A9001

1st byte (01): Version

2nd byte (C4): DeviceType 0xC4— R718CKAB

3rd byte (01): ReportType

4th byte (24): Battery— 3.6v , 24 Hex=36 Dec 36*0.1v=3.6v

5th 6th byte (028A): Temperature— 65°C, 028A(HEX)=650(DEC),650*0.1°C =65.0°C

7th 8th byte (0B0E): Air Temperature— 28.3°C, 0B0E(HEX)=2830(DEC),2830*0.01°C =28.30°C

9th 10th byte (1A90): Air Humidity— 68%, 1A90(HEX)=6800(DEC),6800*0.01%=68.00%

11th byte (01): Threshold Alarm— Low Temperature Alarm, Bit 0 =1



5.2 Example of ConfigureCmd

FPort: 0x07

Bytes	1	1	Var (Fix =9 Bytes)
	CmdID	DeviceType	NetvoxPayLoadData

CmdID– 1 byte

DeviceType– 1 byte – Device Type of Device

NetvoxPayLoadData– var bytes (Max=9bytes)

Description	Device	Cmd ID	Device Type	NetvoxPayLoadData						
Config ReportReq	R718CKAB R718CTAB R718CNAB	0x01	0xC4	MinTime (2bytes) Unit:s	MaxTime (2bytes) Unit:s	Battery Change (1byte) Unit:0.1v	Temperature Change (1byte) Unit:1°C	AirTemperature Change (1byte) Unit:1°C	AirHumid Change (1byte) Unit:1%	Reserved (1Byte) Fixed 0x00
Config ReportRsp		0x81		0xC5	Status (0x00_success)			Reserved (8Bytes,Fixed 0x00)		
ReadConfig ReportReq		0x02	0xCE		Reserved (9Bytes,Fixed 0x00)					
ReadConfig ReportRsp		0x82			MinTime (2bytes) Unit:s	MaxTime (2bytes) Unit:s	Battery Change (1byte) Unit:0.1v	Temperature Change (1byte) Unit:1°C	AirTemperature Change (1byte) Unit:1°C	AirHumid Change (1byte) Unit:1%

(1) Configure R718CKAB report parameters:

MinTime = 1min (0x3c), MaxTime = 1min (0x3c), BatteryChange = 0.1v (0x01), TemperatureChange = 5°C (0x05),

AirTemperatureChange=5°C (0x05), AirHumidChange=5% (0x05)

Downlink: 01C4003C003C0105050500

Response:

81C40000000000000000 (Configuration success)

81C40100000000000000 (Configuration failure)

(2) Read Configuration:

Downlink: 02C40000000000000000

Response: 82C4003C003C0105050500 (Current configuration)

5.3 Example of GlobalCalibrateCmd

FPort: 0x0E

Description	CmdID	Sensor Type	PayLoad (Fix =9 Bytes)						
SetGlobal CalibrateReq	0x01		Channel(1Byte) 0_Channel1, 1_Channel2,etc	Multiplier (2bytes,Unsigned)	Divisor (2bytes,Unsigned)	DeltValue (2bytes,Signed)	Reserved (2Bytes,Fixed 0x00)		
SetGlobal CalibrateRsp	0x81		Channel(1Byte) 0_Channel1, 1_Channel2,etc	Status (1Byte,0x00_success)		Reserved (7Bytes,Fixed 0x00)			
GetGlobal CalibrateReq	0x02		Channel (1Byte,0_Channel1,1_Channel2,etc)			Reserved (8Bytes,Fixed 0x00)			
GetGlobal CalibrateRsp	0x82		Channel(1Byte) 0_Channel1, 1_Channel2,etc	Multiplier (2bytes,Unsigned)	Divisor (2bytes,Unsigned)	DeltValue (2bytes,Signed)	Reserved (2Bytes,Fixed 0x00)		
ClearGlobal CalibrateReq	0x03	Reserved (10Bytes,Fixed 0x00)							
ClearGlobal CalibrateRsp	0x83	Status (1Byte,0x00_success)			Reserved (9Bytes,Fixed 0x00)				

Sensor Type - byte

0x01_Temperature Sensor (Thermocouple temperature & air temperature)

0x02_Humidity Sensor

Channel - byte

0x00_ Thermocouple Temperature

0x01_Air Temperature

0x02_Air Humidity

※Unit:

Thermocouple temperature: 0.1°C

Air temperature: 0.01°C

Air humidity: 0.01%

(1) Calibrate the R718CKAB thermocouple temperature sensor by increasing 10°C

Sensor type:0x01 Channel: 0x00, Multiplier: 0x0001, Divisor: 0x001, DeltValue: 0x0064

Downlink: 0101000001000100640000 // 0064 Hex = 100 Dec, 100*0.1°C=10°C

Response: 81010000000000000000 // Configuration success

8101000100000000000000 // Configuration failure

(2) Read Configuration:

Downlink: 020100000000000000000000

Response: 8201000001000100640000 // Current configuration

5.4 Set/GetSensorAlarmThresholdCmd

Fport:0x10

The threshold value could be configured by users. (Default setting is disabled)

If the sensor shows 0xFFFFFFFF, the high / low threshold function is disabled.

Cmd Descriptor	CmdID (1Byte)	Payload(10Bytes)			
SetSensorAlarm ThresholdReq	0x01	Channel(1Byte) 0x00_Channel1, 0x01_Chanel2, 0x02_Channel3,etc)	SensorType(1Byte) 0x00_Disable ALL Sensor threshold. 0x01_Temperature, 0x02_Humidity,	SensorHigh Threshold (4Bytes)	SensorLow Threshold (4Bytes)
SetSensorAlarm ThresholdRsp	0x81	Status (0x00_success)		Reserved (9Bytes,Fixed 0x00)	
GetSensorAlarm ThresholdReq	0x02	Channel(1Byte, 0x00_Channel1, 0x01_Chanel2, 0x02_Channel3,etc)	SensorType (1Byte,Same as the SetSensorAlarmThresholdReq's SensorType)	Reserved (8Bytes,Fixed 0x00)	
GetSensorAlarm ThresholdRsp	0x82	Channel(1Byte) 0x00_Channel1, 0x01_Chanel2, 0x02_Channel3,etc)	SensorType(1Byte) 0x00_Disable ALL Sensor threshold. 0x01_Temperature, 0x02_Humidity,	SensorHigh Threshold (4Bytes)	SensorLow Threshold (4Bytes)

Channel - 1byte

※ Unit:

0x00_ Thermocouple Temperature

Thermocouple temperature: 0.1°C

0x01_Air Temperature

Air temperature: 0.01°C

0x02_Air Humidity

Air humidity: 0.01%

(1) Set the high threshold to 40.5°C and the low threshold to 10.5°C.

Downlink: 0100010000019500000069 // 195Hex=405Dec,405*0.1°C=40.5°C; 69Hex=105Dec,105*0.1°C=10.5°C.

Device returns: 8100000000000000000000 // Configuration success

(2) GetSensorAlarmThresholdReq

Downlink: 020001000000000000000000

Device returns: 82000100000195000000069


(3) Disable all sensor thresholds. (Configure the Sensor Type to 0)

Downlink: 010000000000000000000000

Device returns: 810000000000000000000000

5.5 Example for MinTime/MaxTime logic


Example#1 based on MinTime = 1 Hour, MaxTime= 1 Hour, Reportable Change i.e. BatteryVoltageChange=0.1V




Note:

MaxTime=MinTime. Data will only be report according to MaxTime (MinTime) duration regardless BatteryVoltageChange value.

Example#2 based on MinTime = 15 Minutes, MaxTime= 1 Hour, Reportable Change i.e. BatteryVoltageChange= 0.1V.



Example#3 based on MinTime = 15 Minutes, MaxTime= 1 Hour, Reportable Change i.e. BatteryVoltageChange= 0.1V.



Note:

- 1) The device only wakes up and performs data sampling according to MinTime Interval. When it is sleeping, it does not collect data.
- 2) The data collected is compared with the last data reported. If the data variation is greater than the ReportableChange value, the device reports according to MinTime interval. If the data variation is not greater than the last data reported, the device reports according to MaxTime interval.
- 3) We do not recommend to set the MinTime Interval value too low. If the MinTime Interval is too low, the device wakes up frequently and the battery will be drained soon.
- 4) Whenever the device sends a report, no matter resulting from data variation, button pushed or MaxTime interval, another cycle of MinTime/MaxTime calculation is started.

6. Information about Battery Passivation

Many of Netvox devices are powered by 3.6V ER14505 Li-SOCl₂ (lithium-thionyl chloride) batteries that offer many advantages including low self-discharge rate and high energy density.

However, primary lithium batteries like Li-SOCl₂ batteries will form a passivation layer as a reaction between the lithium anode and thionyl chloride if they are in storage for a long time or if the storage temperature is too high. This lithium chloride layer prevents rapid self-discharge caused by continuous reaction between lithium and thionyl chloride, but battery passivation may also lead to voltage delay when the batteries are put into operation, and our devices may not work correctly in this situation.

As a result, please make sure to source batteries from reliable vendors, and it is suggested that if the storage period is more than one month from the date of battery production, all the batteries should be activated.

If encountering the situation of battery passivation, users can activate the battery to eliminate the battery hysteresis.

ER14505 Battery Passivation:

6.1 To determine whether a battery requires activation

Connect a new ER14505 battery to a resistor in parallel, and check the voltage of the circuit.

If the voltage is below 3.3V, it means the battery requires activation.

6.2 How to activate the battery

- a. Connect a battery to a resistor in parallel
- b. Keep the connection for 5~8 minutes
- c. The voltage of the circuit should be ≥ 3.3 , indicating successful activation.

Brand	Load Resistance	Activation Time	Activation Current
NHTONE	165 Ω	5 minutes	20mA
RAMWAY	67 Ω	8 minutes	50mA
EVE	67 Ω	8 minutes	50mA
SAFT	67 Ω	8 minutes	50mA

Note:

If you buy batteries from other than the above four manufacturers, then the battery activation time, activation current, and required load resistance shall be mainly subject to the announcement of each manufacturer.

7. Important Maintenance Instruction

Kindly pay attention to the following in order to achieve the best maintenance of the product:

- Keep the device dry. Rain, moisture, or any liquid might contain minerals and thus corrode electronic circuits. If the device gets wet, please dry it completely.
- Do not use or store the device in dusty or dirty environment. It might damage its detachable parts and electronic components.
- Do not store the device under excessive heat condition. High temperature can shorten the life of electronic devices, destroy batteries, and deform or melt some plastic parts.
- Do not store the device in places that are too cold. Otherwise, when the temperature rises to normal temperature, moisture will form inside, which will destroy the board.
- Do not throw, knock or shake the device. Rough handling of equipment can destroy internal circuit boards and delicate structures.
- Do not clean the device with strong chemicals, detergents or strong detergents.
- Do not apply the device with paint. Smudges might block in the device and affect the operation.
- Do not throw the battery into the fire, or the battery will explode. Damaged batteries may also explode.

All of the above applies to your device, battery and accessories.

If any device is not working properly, please take it to the nearest authorized service facility for repair.

8. Description of Waterproof Grade

1: According to Enclosure Protection Class

This standard is equivalent to IEC 60529:2001 Degrees of Protection Provided by Enclosures (IP Code) (English version)

2: The test method of IP65 waterproof grade is: spray the device in all directions under 12.5L/min water flow for 3min, and the internal electronic function is normal.

The test method of IP67 waterproof grade is: the device is immersed in 1m deep water for 30min, and the internal electronic function is normal.

IP65, dust-proof and to prevent damage caused by water from nozzles in all directions from invading electrical appliances. It can be used in general indoor environment and sheltered outdoor environment. It is not suitable for use in environments with high water pressure, high temperature and high humidity, such as long time direct sunlight outdoors and possible direct exposure to rainstorm. If it is really necessary to install in harsh environments, it is recommended to add sunscreen and rainproof shields when installing.



Case I (face down with LED and buttons)



Case II (installed under the rain shield)