
Wireless Activity Detection Sensor

Wireless Activity Detection Sensor**R718MBA****User Manual**

Copyright©Netvox Technology Co., Ltd.

This document contains proprietary technical information which is the property of NETVOX Technology. It shall be maintained in strict confidence and shall not be disclosed to other parties, in whole or in part, without written permission of NETVOX Technology. The specifications are subject to change without prior notice.

Table of Content

1. Introduction	2
2. Appearance	3
3. Main Features	3
4. Set up Instruction	4
5. Data Report	5
5.1 Example of Report Data.....	6
5.2 Example of Config Report time	7
5.3 Example of Config R718MBType	7
5.4 Example of Config Active Threshold.....	8
5.5 Example of Config Restore Report	9
6. Information about Battery Passivation	10
6.1 To determine whether a battery requires activation.....	10
6.2 How to activate the battery	10
7. Relevant Products.....	11
8. Important Maintenance Instruction	11

1. Introduction

It can detect the sudden movement or vibration of the device and send an alarm signal to the gateway for processing. It uses the SX1276 wireless communication module.

LoRa Wireless Technology:

LoRa is a wireless communication technology dedicated to long distance and low power consumption. Compared with other communication methods, LoRa spread spectrum modulation method greatly increases to expand the communication distance. Widely used in long-distance, low-data wireless communications. For example, automatic meter reading, building automation equipment, wireless security systems, industrial monitoring. Main features include small size, low power consumption, transmission distance, anti-interference ability and so on.

LoRaWAN:

LoRaWAN uses LoRa technology to define end-to-end standard specifications to ensure interoperability between devices and gateways from different manufacturers.

2. Appearance



3. Main Features

- Compatible with LoRaWAN
- 2 ER14505 lithium batteries in parallel power supply (3.6V / section)
- IP Rating: IP65/IP67 (Optional)
- Compatible with LoRaWAN™ Class A
- The base is attached with a magnet that can be attached to a ferromagnetic material object
- Frequency hopping spread spectrum
- Configuration parameters can be configured via a third-party software platform, data can be read and alerts can be set via SMS text and email (optional)
- Applicable to third-party platforms: Actility/ThingPark, TTN, MyDevices/Cayenne
- Low power consumption and long battery life

Battery Life:

- Please refer to web: http://www.netvox.com.tw/electric/electric_calc.html
- At this website, users can find battery life time for variety models at different configurations.

4. Set up Instruction

On/Off

Power on	Insert batteries. (Users may need a screwdriver to open)
Turn on	Press and hold the function key for 3 seconds till the green indicator flashes once.
Turn off (Restore to factory setting)	Press and hold the function key for 5 seconds till green indicator flashes for 20 times.
Power off	Remove Batteries.
Note	<ol style="list-style-type: none"> 1. Remove and insert the battery; the device is at off state by default. 2. On/off interval is suggested to be about 10 seconds to avoid the interference of capacitor inductance and other energy storage components. 3. At 1st -5th second after power on, the device will be in engineering test mode.

Network Joining

Never joined the network	<p>Turn on the device to search the network to join.</p> <p>The green indicator stays on for 5 seconds: success</p> <p>The green indicator remains off: fail</p>
Had joined the network (not at factory setting)	<p>Turn on the device to search the previous network to join.</p> <p>The green indicator stays on for 5 seconds: success</p> <p>The green indicator remains off: fail</p>

Function Key

Press and hold for 5 seconds	<p>Restore to factory setting / Turn off</p> <p>The green indicator flashes for 20 times: success</p> <p>The green indicator remains off: fail</p>
Press once	<p>The device is in the network: green indicator flashes once and sends a report</p> <p>The device is not in the network: green indicator remains off</p>

Sleeping Mode

The device is on and in the network	<p>Sleeping period: Min Interval.</p> <p>When the report change exceeds setting value or the state changes: send a data report according to Min Interval.</p>
-------------------------------------	---

Low Voltage Warning

Low Voltage	3.2V
-------------	------

5. Data Report

Data will be reported once per hour by default setting.

Default Setting:

Maximum time: 0x0E10 (3600s)

Minimum time: 0x0E10 (3600s) // Detect the current voltage value every 3600s by default setting

Battery Change: 0x01 (0.1V)

R718MBA Vibration:

When the device detects a sudden movement or vibration and changes the stationary state, it immediately sends a report. After the vibration alarm, the device needs to enter the stationary state and wait for 5 seconds before starting for the next detection. If the vibration continues to occur during this process, the 5 seconds timing restarts until it enters the stationary state.

Active Threshold:

Active threshold range is 0x0003-0x00FF (default is 0x0003, the most sensitive)

Active Threshold = Critical value \div 9.8 \div 0.0625

* The gravitational acceleration at standard atmospheric pressure is 9.8 m/s²

* The scale factor of the threshold is 62.5 mg

R718MB DeviceType:

0x01_R718MBA

0x02_R718MBB

0x03_R718MBC

The default value is the programming value.

Note:

1. The device report interval will be programmed based on the default firmware which may vary.
2. The interval between two reports must be the minimum time.

Please refer Netvox LoRaWAN Application Command document and Netvox Lora Command Resolver

<http://cmddoc.netvoxcloud.com/cmddoc> to resolve uplink data.

Data report configuration and sending period are as following:

Min. Interval (Unit:second)	Max. Interval (Unit:second)	Reportable Change	Current Change \geq Reportable Change	Current Change $<$ Reportable Change
Any number between 1~65535	Any number between 1~65535	Can not be 0.	Report per Min. Interval	Report per Max. Interval

5.1 Example of Report Data

FPort: 0x06

Bytes	1	1	1	Var(Fix=8 Bytes)
	Version	DeviceType	ReportType	NetvoxPayLoadData

Version– 1 byte –0x01—the Version of NetvoxLoRaWAN Application Command Version

DeviceType– 1 byte – Device Type of Device

The devicetype is listed in Netvox LoRaWAN Application Devicetype doc

ReportType – 1 byte –the presentation of the NetvoxPayLoadData, according the devicetype

NetvoxPayLoadData– Fixed bytes (Fixed =8bytes)

Device	Device Type	Report Type	NetvoxPayLoadData		
R718MBA	0x27	0x01	Battery (1Byte,unit:0.1V)	Status (1Byte 0:off 1:on)	Reserved (6Bytes,fixed 0x00)

Example 1 of Uplink: 0127012401000000000000

1st byte (01): Version

2nd byte (27): DeviceType—R718MBA

3rd byte (01): ReportType

4th byte (24): Battery—3.6v , 24 Hex=3.6Dec 36*0.1v=3.6v

5th byte (01): Status—on

6th ~ 11th byte (000000000000): Reserved

Example 2 of Uplink: 0127019F00000000000000

1st byte (01): Version

2nd byte (27): DeviceType—R718MBA

3rd byte (01): ReportType

4th byte (9F): Battery—3.1v , 1F Hex=31Dec 31*0.1v=3.1v // Low battery

5th byte (00): Status—off

6th ~ 11th byte (000000000000): Reserved

Note:

When the battery is low voltage, the highest bit of the voltage is 1, and bit0-bit6 represents the voltage value.

5.2 Example of Config Report Time

FPort: 0x07

Bytes	1	1	Var (Fix =9 Bytes)
	CmdID	DeviceType	NetvoxPayLoadData

CmdID– 1 byte

DeviceType– 1 byte – Device Type of Device

NetvoxPayLoadData– var bytes (Max=9bytes)

Description	Device	Cmd ID	Device Type	NetvoxPayLoadData			
Config ReportReq	R718MBA	0x01	0x27	MinTime (2bytes Unit:s)	MaxTime (2bytes Unit:s)	BatteryChange (1byte Unit:0.1v)	Reserved (4Bytes,Fixed 0x00)
Config ReportRsp		0x81		Status (0x00_success)		Reserved (8Bytes,Fixed 0x00)	
ReadConfig ReportReq		0x02		Reserved (9Bytes,Fixed 0x00)			
ReadConfig ReportRsp		0x82		MinTime (2bytes Unit:s)	MaxTime (2bytes Unit:s)	BatteryChange (1byte Unit:0.1v)	Reserved (4Bytes,Fixed 0x00)

(1) Configure device parameters MinTime = 5 min, MaxTime = 5min, Battery Change = 0.1v

Downlink: 0127012C012C0100000000 // 012C (Hex) = 300(Dec)

The device returns:

812700000000000000000000 // Configuration is successful

812701000000000000000000 // Configuration failed

(2) Read device parameters

Downlink: 022700000000000000000000

The device returns: 8227012C012C0100000000 // Current device parameters

5.3 Example of Config R718MBType

FPort: 0x07

Description	Device	Cmd ID	Device Type	NetvoxPayLoadData	
SetR718MB TypeReq	R718MBA	0x03	0x27	R718MBType(1Byte) 0x01_R718MBA 0x02_R718MBB	Reserved (8Bytes,Fixed 0x00)

				0x03_R718MBC	
SetR718MB TypeRsp		0x83		Status (0x00_success)	Reserved (8Bytes,Fixed 0x00)
GetR718MB TypeReq		0x04		Reserved (9Bytes,Fixed 0x00)	
GetR718MB TypeRsp		0x84		R718MBType(1Byte) 0x01_R718MBA 0x02_R718MBB 0x03_R718MBC	Reserved (8Bytes,Fixed 0x00)

(3) Change the device type to R718MBB

Downlink: 032702000000000000000000

The device returns:

832700000000000000000000 // Configuration succeeded

832701000000000000000000 // Configuration failed

(4) Check the current device type

Downlink: 042700000000000000000000

The device returns: 842702000000000000000000 // Current device type is R718MBB

5.4 Example of Config Active Threshold

FPort: 0x07

Description	Device	Cmd ID	Device Type	NetvoxPayLoadData		
SetActive ThresholdReq	R718MBA	0x05	0x27	Threshold (2Bytes)	Deactivetime (1Byte,Unit:1s)	Reserved (6Bytes,Fixed 0x00)
SetActive ThresholdRsp		0x85		Status (0x00_success)	Reserved (8Bytes,Fixed 0x00)	
GetActive ThresholdReq		0x06		Reserved (9Bytes,Fixed 0x00)		
GetActive ThresholdRsp		0x86		Threshold (2Bytes)	Deactivetime (1Byte,Unit:1s)	Reserved (6Bytes,Fixed 0x00)

(5) Assuming the threshold is 10m/s², the value that needs to be set is $10/9.8/0.0625=16.32$, the last value is 16.32 which needs to be taken an integer, and the configuration is 16.

Configure device parameters Threshold= 16, Deactivetime=10s

Downlink: 052700100A000000000000 // 10 (Hex) = 16(Dec), 0A (Hex) = 10(Dec)

The device returns:

8527000000000000000000 // Configuration succeeded

8527010000000000000000 // Configuration failed

(6) Read device configuration parameters

Downlink: 0627000000000000000000

The device returns: 862700100A000000000000 (current device configuration parameters)

5.5 Example of Config Restore Report

FPort: 0x07

RestoRereportSet = 0x00, only sends vibration data (Default)

RestoRereportSet = 0x01, sends vibration data and vibration stop data

* The function of *Restore* is supported by the firmware version after 20200330 version.

Description	Device	Cmd ID	Device Type	NetvoxPayloadData	
SetRestore ReportReq	R718MBA	0x07	0x27	RestoreReportSet(1byte) 0x00_DO NOT report when sensor restore 0x01_DO report when sensor restore	Reserved (8Bytes,Fixed 0x00)
SetRestore ReportRsp		0x87		Status (0x00_success)	Reserved (8Bytes,Fixed 0x00)
GetRestore ReportReq		0x08		Reserved (9Bytes,Fixed 0x00)	
GetRestore ReportRsp		0x88		RestoreReportSet(1byte) 0x00_DO NOT report when sensor restore 0x01_DO report when sensor restore	Reserved (8Bytes,Fixed 0x00)

(7) Configure Do report when sensor restore

Downlink: 0727010000000000000000

The device returns: 8727000000000000000000 // Configuration success

8727010000000000000000 // Configuration failure

(8) Read device parameter:

Downlink: 0827000000000000000000

The device returns: 8827010000000000000000 // Current configuration

6. Information about Battery Passivation

Many of Netvox devices are powered by 3.6V ER14505 Li-SOCl₂ (lithium-thionyl chloride) batteries that offer many advantages including low self-discharge rate and high energy density.

However, primary lithium batteries like Li-SOCl₂ batteries will form a passivation layer as a reaction between the lithium anode and thionyl chloride if they are in storage for a long time or if the storage temperature is too high. This lithium chloride layer prevents rapid self-discharge caused by continuous reaction between lithium and thionyl chloride, but battery passivation may also lead to voltage delay when the batteries are put into operation, and our devices may not work correctly in this situation.

As a result, please make sure to source batteries from reliable vendors, and it is suggested that if the storage period is more than one month from the date of battery production, all the batteries should be activated.

If encountering the situation of battery passivation, users can activate the battery to eliminate the battery hysteresis.

ER14505 Battery Passivation:

6.1 To determine whether a battery requires activation

Connect a new ER14505 battery to a resistor in parallel, and check the voltage of the circuit.

If the voltage is below 3.3V, it means the battery requires activation.

6.2 How to activate the battery


- a. Connect a battery to a resistor in parallel
- b. Keep the connection for 5~8 minutes
- c. The voltage of the circuit should be ≥ 3.3 , indicating successful activation.

Brand	Load Resistance	Activation Time	Activation Current
NHTONE	165 Ω	5 minutes	20mA
RAMWAY	67 Ω	8 minutes	50mA
EVE	67 Ω	8 minutes	50mA
SAFT	67 Ω	8 minutes	50mA

Note:

If you buy batteries from other than the above four manufacturers, then the battery activation time, activation current, and required load resistance shall be mainly subject to the announcement of each manufacturer.

7. Relevant Products

Model	Function	Appearance
R718MBA	Detect the movement or vibration of the device and triggers an alarm.	
R718MBB	Counts the number of movements or vibrations of the device.	
R718MBC	Counts the movement or vibration duration of the device.	

8. Important Maintenance Instruction

Your device is a product of superior design and craftsmanship and should be used with care. The following suggestions will help you use the warranty service effectively.

- Keep the equipment dry. Rain, moisture, and various liquids or moisture may contain minerals that can corrode electronic circuits. In case the device is wet, please dry it completely.
- Do not use or store in dusty or dirty areas. This can damage its detachable parts and electronic components.
- Do not store in excessive heat. High temperatures can shorten the life of electronic devices, destroy batteries, and deform or melt some plastic parts.
- Do not store in a cold place. Otherwise, when the temperature rises to normal temperature, moisture will form inside, which will destroy the board.
- Do not throw, knock or shake the device. Rough handling of equipment can destroy internal circuit boards and delicate structures.
- Do not wash with strong chemicals, detergents or strong detergents.
- Do not apply with paint. Smudges can block debris in detachable parts and affect normal operation.
- Do not throw the battery into a fire to prevent the battery from exploding. Damaged batteries may also explode.

All of the above suggestions apply equally to your device, battery and accessories. If any device is not working properly.

Please take it to the nearest authorized service facility for repair.